



Scheibe 1: 4/GH1/4/16/5

Dichtprofile



— Q-LON 3019  
 $R_W = 39 \text{ dB}$



— VDW 02  
 $R_W = 36 \text{ dB}$




- - - VDW 11/28  
 $R_W = 40 \text{ dB}$




Scheibe 2: 12/16/4

Dichtprofile

— Q-LON 3019  
 $R_W = 37 \text{ dB}$



— VDW 02  
 $R_W = 33 \text{ dB}$



- - - VDW 11/28  
 $R_W = 38 \text{ dB}$





Bild 1 Schalldämm-Maß R des Fensters mit den verschiedenen Dichtungen